

SPE-0104

DR-104

SE-85-405
SL-100-626
SL-100-318

St. John's, June 12, 1967.

Ferranti-Packard Electric Limited,
St. Catharines,
Ontario.

Attention: Mr. W. L. Mills,
Manager of Engineering;
Instrument Transformers.

SPECIAL APPROVAL - Two Only - Ferranti-Packard Type "P5"
Current Transformers, 1000/2000/3000-5
Amps., Serial Numbers 2-204132 and
2-204133

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to the above-named apparatus.

These transformers are similar in design to the double-ratio transformers receiving approval under Circular ST-PA.313 except that they have an extra secondary terminal marked "Y" which, in conjunction with "X1", provides the 3000-5 amp. ratio. The remaining terminals are marked "X2" and "X3" providing the 1000-5 and 2000-5 amp. ratios respectively with "X1".

The accuracy rating is 0.3%0.2;0.6%0.2(2x0.2),P2.0 on the 1000-5 ratio and 0.3%2.0 on the other two ratios; and the nameplates are marked "0.3%0.2".

These transformers are for use by Newfoundland Limited.

Yours very truly,

EAW/ccc

F. Dryer, Chief,
Electricity and Gas Division,
Standards Branch.

c.c. to: Mr. J. M. Taylor, District Inspector of Elec. and Gas, St. John's
c.c. to: Newfoundland Limited (through Mr. Taylor)