

SE-85-36  
SL-100-76(N)  
SL-100-SPE

Ottawa, July 5, 1967.

Canadian Allis-Chalmers Limited,  
P. O. Box 37,  
Montreal,  
P. Q.

Attention: Mr. H. Schmah,  
Electrical Department

SPECIAL APPROVAL - Two Only - Canadian Allis-Chalmers  
Type "C.D.W." 400-5 Amp., 60 Hz.  
Current Transformers, Serial Numbers  
C 258440 and C 258441


Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to the above-named apparatus.

The accuracy rating was found to be 0.380.1, 0.2, 0.5, 0.9, B(2x0.9), 1.0, and B2.0, and the nameplates were marked "0.380.9".

These transformers are for the St. Lawrence Cement Company, Ogden Point Quarry, South of Highway No.2, Port Colborne, Ontario.

Yours very truly,



(for) Chief, Electricity & Gas Division,  
Standards Branch.

EAM/mcc

c.c. to: Mr. C. D. Briggs, Dist. Insp. of Electricity & Gas, Hamilton  
c.c. to: St. Lawrence Cement Company (through Mr. Briggs)