

SPE-0107

SP-107

100-100-57
100-100-57
100-100-57

October 10, 1957

Bedford-Manors Limited,
117 Leinster Road, Dublin,
Ireland.

Attention: Mr. J. Casson, Eng.,
Manufacturing Division.

SPECIAL APPROVAL - Four only - Canadian Westinghouse
Type 15 for 5000/2500-5 Amp.,
Current Transformers, Serial Numbers
51340, 51342, 51343 and 51344

Dear Sirs:

This is to advise that Special Approval has been granted
by the Standards Branch for use in Canada for Billings used in
the above-named Current Transformer.

These transformers have a 60 Hz. relative accuracy rating
of 10/200 marked on their nameplates, but as a result of our tests,
these transformers have been granted a relative accuracy rating of
0.302.0, which applies to both ratios but is not marked on the
nameplates.

These units are for use by Bedford-Manors Limited
at Grand Falls, Newfoundland.

Very truly,
Yours,

J. J. Power, Chief,
Engineering and Inspection
Standards Branch.

c.c. to: Mr. J. L. Taylor, District Engineer of Eng. and Insp. Div. (100-100-57)
c.c. to: Mr. J. L. Taylor, District Engineer of Eng. and Insp. Div. (100-100-57)