

SE-85-1-5
SL-100-50(R)
SL-100-3PR

Ottawa, October 6, 1967.

Ferranti-Packard Electric Limited,
ST. CATHARINES,
Ontario.

Attention: Mr. F. L. Mills,
Manager of Engineering,
Instrument Transformers.

SPECIAL APPROVAL - Three Only - Ferranti-Packard
Type "F138" 400/800-5 amps.,
138000 volts, 60 hz, Outdoor
Oil-Insulated Current Transformers,
Serial Numbers 2-214932, 2-214933,
2-214934

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch, for use in Canada for billing purposes, to the above-named apparatus.

The double ratio is obtained by means of a series/parallel primary, and the accuracy marked on the nameplate covering both ratios is "0.3%0.9".

These units are for the Calgary Power Company Limited for use in the East Calgary Substation, Calgary, Alberta.

Yours very truly.

W. J. S. Fraser, Chief,
Electricity and Gas Division,
Standards Branch.

EAW/nee

c.c. to Mr. A. G. Fark, Dist. Insp. of Electricity and Gas, Calgary
c.c. to Calgary Power Company Limited (through Mr. Fark)