

SE-85-4-5  
 SL-100-983(U)  
 SL-100-SPE

Ottawa, December 26, 1967.

Ferranti-Packard Electric Limited,  
 St. Catharines,  
 Ontario.

Attention: Mr. E. L. Mills,  
 Manager of Engineering,  
 Instrument Transformers.

SPECIAL APPROVAL - Three Only - Ferranti-Packard Type "RP"  
 2000/1200/800-5 Amp. Current Transformers.  
 Serial Numbers 2-215738, 2-215739 and  
 2-215740

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch, for use in Canada for billing purposes, to the above-named apparatus.

The accuracy rating of these transformers is 0.3B2.0 on the 2000-5 and 1200-5 ratios and 0.3B1.0;0.6B2.0 on the 800-5 ratio. all at R.F.= 2.0.

These transformers will be installed in a power transformer, serial number 1-3054, rated at 5000kva, 27600 volts primary and 4160Y/2400 volts secondary. The power transformer will be used by the Tecumseh Public Utilities Commission at Oldcastle, Ontario.

The metering accuracy of the type "RP" current transformers marked on the nameplates is 0.6B(2x0.9) for the 800-5 ratio and 0.3B(2x0.9) for the 1200-5 and 2000-5 ratios.

The terminals to be used to obtain the desired ratio for metering purposes are indicated on the nameplate.

Yours very truly,

W. J. S. Fraser, Chief,  
 Electricity and Gas Division,  
 Standards Branch.

EAW/mee

c.c. to: Mr. J. Fleming, Dist. Insp. of Electricity and Gas, London  
 c.c. to: Tecumseh Public Utilities Commission (through Mr. Fleming)