

CS-35-2-1
SL-100-659(T)
SL-100-SPE

Ottawa, March 11, 1968.

SPECIAL APPROVAL

Granted to: Saskatchewan Power Corporation,
1739 Cornwall Street,
Regina, Saskatchewan.


Subject: Canadian Westinghouse 5-dial x 1 Cyclometer
Registers with mask over first reading drum
on Saskatchewan Power Corporation's Canadian
Westinghouse "D2A" and "D3A" Meters.

(Attention: Mr. W. G. Thompson,
Metering & Transformer Engineer)

Special Approval has been granted by the Standards Branch
for the use of the above-noted register on Canadian Westinghouse
types "D2A" and "D3A" single-phase watt-hour meters of the Saskatchewan
Power Corporation.

This approval is contingent upon mutually satisfactory
arrangements being made between the utility and the Regina district
office which will ensure that the time needed for the inspection and
test of these meters is not significantly increased. It will be con-
sidered satisfactory if such arrangement requires the dial test to be
made with the meter cover off and the mask removed. All accuracy
tests, however, must be made with the cover in place and the mask
installed.

The register must be marked "mult x 10"; a decal to the same
effect may be attached to the inner side of the glass cover if the
utility so desires, but the sticker must be put in such a place that
if it becomes detached it will not fall on the working parts of the
meter.



(W.J. S. Fraser)
Chief, Electricity and Gas Division,
Standards Branch.

WJSF/mcc

c.c. to: Mr. J. Duff, Acting Dist. Insp. of Elec. and Gas, Regina