

1-10-1
 1-10-1
 1-10-1

OTTAWA, April 9, 1909.

OFFICIAL LETTER

Granted to: Saskatchewan Power Corporation,
 1739 Cornwall Street,
 Regina, Saskatchewan.

Subject: Canadian Westinghouse 5-dial Type Cyclometer
 Registers with mask over first reading drum
 on Saskatchewan Power Corporation Canadian
 Westinghouse "C" meters.

(Attention: Mr. W. D. Thompson,
 Metering & Transformer Engineer)

Special Approval has been granted by the Steam and Branch
 for the use of the above-noted register on Canadian Westinghouse Type "C"
 single phase watt-hour meters of the Saskatchewan Power Corporation.

This approval is contingent upon mutually satisfactory
 arrangements being made between the utility and the Regins district office
 which will ensure that the time needed for the test and inspection of these
 meters is not significantly increased. It will be considered satisfactory
 if such arrangement requires the dial test to be made with the cover off
 and the mask removed. All accuracy tests, however, must be made with the
 cover in place and the mask installed.

The register must be marked "Permitted" in red ink. The same
 effect may be attained to the lower side of the glass cover by the utility
 electrician, but the sticker must be put in such a position that it does not
 detract in any way from the working parts of the meter.

Covers used must be such that there is no interference
 for the dial face of the register.

(S. D. Thompson,
 Chief,
 Metering and Transformer Division,
 Saskatchewan Power Corporation)

c.c. Mr. J. Huff, Acting Dist. Insp. of Elec. and Gas, Regina.