

SE-85-5-3  
SL-100-353(R)  
SL-100-SFE

Ottawa, May 23, 1968.

SPECIAL APPROVAL

Granted to: The Hydro-Electric Commission of Etobicoke,  
Municipal Centre,  
2 Bridgeway Street,  
Etobicoke, Ontario.

Subject: Two Only - English Electric Type "EO-27"  
27600-115 Volt Potential Transformers,  
Serial Numbers 176775 and 200597.

(Attention: Mr. W. Rodsell,  
Consumer Service.)

Special Approval has been granted by the Standards Branch,  
for use in Canada for billing purposes, to the above-noted trans-  
formers.

These transformers have an accepted accuracy rating of  
1.2WXYZ, 3Z.

We would like to point out that there may be some doubt  
as to the polarity of the secondary leads.

W. J. S. Fraser, Chief,  
Electricity and Gas Division,  
Standards Branch

EAM/mee

c.c. to: Mr. W. R. McEown, District Inspector of Electricity and Gas, Toronto  
c.c. to: Ontario Hydro - (attention: Mr. R. A. Thompson, Protection  
and Control Engineer - Operations)  
- (through Mr. McEown)