SE-05-36 SL-100-76-0 SL-100-SPE

Ottawa, Pay 27, 1968.

SEECTAL APPROVAL

Granted to: Canadian Allis-Chalmers Limited,

P.O. Box 37, Montreal, Quebec.

Subject: Four Only Canadian Allie-Chalmers

Type "CDw" 600-5 App. Current Transformers

Serial Humbers 259970-71-72-73.

Attention: Mr. II. Schmah,

Electrical Department.

Special Approval has been granted by the Standards Branch, for use in Canada for billing our oses, to the above-named apparatus.

These transformers are of moulded type with primary bars extending vertically from the body of the transformer. Each transformer has a single untepped secondary uinding terminating in solderless connectors in a moulded recess near the top of the transformer. Primary and secondary polarity is indicated by white dots moulded in the body.

The accuracy rating is 0.300.1, B0.2, B0.5, B0.9, B1.0, B(2x0.9), B2.0 with a rating factor of 1.5 and the nameplates are marked 0.3B1.0 R.F.=1.5.

These transformers are installed at British Columbia Molybdenum Ltd., h02 West Pender Street, Vencouver, B.C.

W.J.S. Fraser, Chief,

Electricity and Gas Division,

W/ Tamera

Standards Brauch.

c.c. Ur. R.G.D. Ward, D.I. of Electricity and Uss, Vancouver, B. C. c.c. to Molybdenum Ltd (through Mr. Ward)