

SL-85-4-5  
 SR-85-4-5  
 SL-100-5961  
 SL-100-SPE

OTTAWA, July 4, 1968.

SPECIAL APPROVAL

Granted to: Ferranti-Packard Electric Limited,  
 St. Catharines,  
 Ontario.

Subject: Two Only Packard Type "VE-46" 27500/17500Y-110  
 Volts, 125/250/500/100-5 amp., 60 Hz Outdoor  
 Oil Insulated Metering Outfits, serial numbers  
 174923 and 174924.

Attention: Mr. E. L. Mills,  
 Manager of Engineering,  
 Instrument Department.

Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to the above-named apparatus.

Metering outfit number 174923 contains two type "CC" voltage transformers, serial numbers 174919 and 174920 and three type "CC" current transformers serial numbers 174913, 174914 and 174915.

Metering outfit number 174924 contains two type "CC" voltage transformers serial numbers 174921 and 174922 and three type "CC" current transformers serial numbers 174916, 174917 and 174918.

The accuracy ratings are 0.38% for the voltage transformers and 0.68% on all ratios for the current transformers.

Both metering outfits were supplied to the Beaudouin Light, Heat and Power Company in 1953 and outfit number 174923 is now in service by Quebec Hydro at Chromium Lining and Smelting, Beaudouin, Quebec.

EAM/mh

M. J. S. Fraser, Chief,  
 Electricity and Gas Division,  
 Standards Branch.

c.c. Mr. J. P. Dumas, District Inspector of Electricity and Gas, Montreal.  
 c.c. Chromium Lining and Smelting (through Mr. Dumas).