

112-101  
SPE-0131-174  
S.E. Standard

OTTAWA, July 29, 1960.

RECEIVED AND FILED

Granted to I.T.E. Circuit Breaker (Canada) Ltd.  
Eastern Power Devices Division,  
2401 Davis Road,  
Port Credit, Ontario.

Subject: Four sets, I.T.E. Circuit Breaker Type ICB-15A  
Current Transformers, 15 kV.,  
3000/1500/1000/500/100-5 - 5 ratios.  
Serial numbers 2719, 1910, 1921, 1922

The sets, I.T.E. Circuit Breaker Type ICB-15B  
1200/1000/800/600/400/300/200/100-5 ratios.  
Serial numbers 1917, 1944

Attention: Mr. W. L. Gardner,  
Chief Inspector,  
Transformer, Heating  
and Capacitor Section.

Special Approval has been granted by the Standards Branch, for use in Canada for military purposes, to the above-named apparatus.

These transformers are through type with tapped secondary windings.

For the four type ICB-15A units the approval is limited to the 3000/5 and 2000/5 ratios. The accuracy rating at these ratios was found to be 0.3 D.O.1, 10.2, 10.5, 10.9, 11.0, 1(±0.9), 13.0, and the nameplates are stamped 0.3 10.2, 10.5, 10.9; 0.6 1(±0.9) on 3000A and 2000A Taps.

For the two type ICB-15B units the approval is limited to the 1000/5 and 500/5 ratios. The accuracy rating at the 1000/5 ratio was found to be 0.3 10.1, 10.9, 1(±0.9), 13.0, and at the 500/5 ratio was found to be 0.3 10.1, 10.5, 10.9, 11.0, 1(±0.9); 0.6 12.0. Nameplates are stamped 0.3 10.2, 10.5, 10.9; 0.6 1(±0.9) on 1000A and 500A Taps.

These transformers are for use at the Ottawa-Medroff Transformer Station of Ontario Hydro.

*W. J. S. Frazer*

W. J. S. Frazer, Chief,  
Electricity and Gas Division,  
Standards Branch.

c.c. Mr. W. F. Miller, District Inspector of Electricity and Gas, Ottawa  
c.c. Ontario Hydro (through Mr. Miller)