

61-100-SPE

61-69-10

OTPA A, August 7, 1968.

SPECIAL APPROVAL

Granted to: Hydro - Quebec,
Richelieu Region,
Montreal, P. .

Subject: One 1600Watt-Dum relay
Type 616XX16/110
115 Volts, 60 Cycle

One Industrial alarm clock
Timing interval
Model C2
115 Volts, 60 Cycle

Special Approval has been granted by the Standards Branch,
for use in Canada for billing purposes, to the above-named apparatus.

The 1600Watt-Dum relay is energized when the 100 lead
exceeds a preset value by an auxiliary contact on the 100 carrier.
It, in turn, controls the potential supply to a second watt-hour meter,
and to the running time meter named above.

This equipment is approved for use only in connection with
Hydro-Quebec installation No. T-38, at Chartrand In or and Swelling Co.,
Leauzonville.

This approval is conditional upon the installation being
accepted by the District Inspector of Electricities and Gas, Montreal.

J. A. Brown,
Chief,
Electricity and Gas Division,
Standards Branch.

c.c. Mr. J. B. Dumas, District Inspector (E&G) Montreal

Hydro - Quebec. (through Mr. Dumas)