

SPE-133

SI-100-SPE

SE-69-10

OTTAWA, August 7, 1968.

SPECIAL APPROVAL

Granted to: Hydro - Quebec,
Richelieu Region,
Montreal, P. Q.

Subject: One C.G.E. Co. Relay
Model 12 HMA 11A31
115 Volts, 60 Cycles

One Sodaco Geneva Clock
Type EH5. No. 608

Special Approval has been granted by the Standards Branch,
for use in Canada, for billing purposes, to the above-named apparatus.

The type HMA relay is energized when the load exceeds a pre-
determined value, by an auxiliary contact on the Kw. recorder. It
in turn, controls the potential supply to a second watt-hour meter, and
to the clock described above.

This equipment is approved for use only in connection with
Hydro-Quebec installation No. 799901-12000, at Union Carbide Co.,
Beauharnois.

This approval is conditional upon the installation being
acceptable to the District Inspector of Electricity and Gas, Montreal.

W. J. S. Fraser,
Chief,
Electricity and Gas Division,
Standards Branch.

DLE/sw

c.c. Mr. J. B. Dumas District Inspector (E&G) Montreal

Hydro-Quebec, (through Mr. Dumas)