

SPE-0134

100-134

100-1-5

100-50 (c)

100-826

August 29, 1968

TEST REPORT

Requested by: **British Columbia Electric Limited,  
11, Columbia,  
Vancouver.**

Subject: **Three 240V British Columbia Type "B13"  
1000 VA, 120/240 Volt, 60 Hz. Indoor  
All Purpose Current Transformers,  
Serial Numbers 2-44472, 2-44473, 2-44474.**

Attention: **Mr. H. G. Mills,  
Manager of Engineering,  
Indoor Transformers.**

Partial Approval has been granted by the Standards Branch,  
for use in tests for billing purposes, to the above listed apparatus.

The dielectric ratio is obtained by means of a series/parallel primary,  
and the accuracy rating based on the approximate value of the ratio  
is "0.3%".

These transformers are for the British Columbia Electric Power  
Company Ltd., Vancouver, B. C.

*[Handwritten Signature]*  
Chief,  
Electrical Inspection,  
Standards Branch.

100-1-5 (c)  
100-50 (c)