

SI-195  
SI-150-974(G)  
SI-100-918

OTTAWA,

October 22, 1948

SPECIAL APPROVAL

Granted to: I.T.E. Circuit Breaker (Canada) Limited,  
Eastern Power Devices Division,  
2401 Main Road,  
North York, Ontario.

Subject: One unit, I.T.E. Circuit Breaker Type CB11507  
Current Transformer, 15kv  
3000/2500/2000/1500-5 Amp.  
Serial number 2510.

Attention: Mr. E. W. Gardner, Chief Engineer,  
Transformer, Rectifier & Capacitor Section.

Special Approval has been granted by the Standards Branch, for  
use in Canada for billing purposes, to the above-named apparatus.

This transformer is a through type with a tapped secondary  
winding.

This approval is restricted to the 2000-5 and 2500-5 ratios for  
which the nameplate is stamped 0.3 3.0; 0.5 (2000).

This transformer is for use at the Ottawa Suburban Station of  
Ontario Hydro.

J. L. ...  
Chief,  
Electricity and Gas Division  
Standards Branch.

C. E. ...  
Ontario Hydro (through C. Miller)