

SFE-137
SE-35-76
SL-100-E
SL-100-SFE

OTTAWA, November 26, 1968.

SPECIAL APPROVAL

Granted to: Kingston Public Utilities Commission,
P.O. Box 790,
Kingston, Ontario.


Subject: One only, Moloney Type "POT" Voltage Transformer
2300-115 volts, .050 kva, 60 hz serial 99390

Attention: Mr. C. Marlow,
Meter Supervisor

Special Approval has been granted by the Standards Branch
for use in Canada for billing purposes to the above-named apparatus.

This transformer is a pole type with a single secondary
winding and has a 60hz accuracy rating of 0.3%±0.6%.

This transformer is for use by Kingston Public Utilities
Commission.



W.J.S. Fraser,
Chief,
Electricity and Gas Division,
Standards Branch.

c.c. Mr. T.G. Murphy, D.I. of E&G, Belleville.