

SI-100-SPE 138

SE-6-10

SE-35-2-6

SE-35-2-7

OTTAWA, December 6, 1968.

SPECIAL APPROVAL

Granted to: Hydro-Quebec
Montreal, P.Q.

Subject: Two, only, Canadian Westinghouse Outdoor, oil insulated Metering Equipment. Each containing three current and three voltage transformers as follows:

Unit for line #2: Current Transformers serial Nos. 198304, 198307, 205306, ratio 600/300 to 5 amps. Voltage transformers, serial Nos. 198283, 198284, 205312, ratio 80,000 to 133 1/3 - 133 1/3/80 volts.

Unit for line #4: Current transformers serial Nos. 205307, 205308, 198309, ratio 600/300 to 5 amps. Voltage transformers, serial Nos. 205313, 205314, 198288, ratio 80,000 to 133 1/3 - 133 1/3/80 volts.

Special Approval has been granted by the Standards Branch, for use in Canada for billing purposes, to the above-named apparatus.

This equipment is installed at the Canadian Electrolytic Zinc Company, Valleyfield, Quebec.

W.J.S. Fraser,
Chief,
Electricity and Gas Division,
Standards Branch.

c.c. Mr. J. B. Dumas, District Inspector of E&G, Montreal, Quebec.