

SFE-139

SE-85-36
SL-100-76 (U)
SL-100-SPE

OTTAWA, December 12, 1968.

SPECIAL APPROVAL

Granted to: Canadian Allis-Chalmers
P.O. Box 37,
Montreal, Quebec.

Subject: Seven only, Canadian Allis-Chalmers Type "CDIM"
1500-5 amp., 60 hz Current Transformers, serial
numbers 1071-01, -02, -03, -04, -05, -06, -07.

Attention: Mr. H. Schmah,
Electrical Department.

Special Approval has been granted by the Standards Branch
for use in Canada for billing purposes, to the above-named apparatus.

These transformers are through type with a single untapped secondary
winding, and the accuracy rating is 0.3B2.0 at 60 hz.

They are for use by the Etobicoke Hydro Electric Commission
and will be incorporated in Canadian Allis-Chalmers 4160 volt switch-
gear for Metropolitan Toronto Richview Pumping Station.

W.J.S. Fraser,
Chief,
Electricity and Gas Division,
Standards Branch.

c.c. Mr. W. R. McEown, D.I. of Toronto
Etobicoke Hydro (through Mr. McEown)