

SPS -140

SE-35-4-5
SL-100-50 (D)
SL-100-SPE

OTTAWA, December 13, 1968.

SPECIAL APPROVAL

Granted to: Ferranti-Packard Electric Limited
St. Catharines, Ontario.

Subject: Three Only, Ferranti-Packard Type "K138"
400/200-5 Amps., 138,000 volts 60 hz
Outdoor Oil Insulated Current Transformers
Serial numbers 2-207165-166-167

Attention: Mr. E. L. Mills, Manager of Engineering
Instrument Transformers

Special Approval has been granted by the Standards Branch
for use in Canada for billing purposes to the above-named
apparatus.

The double ratio is obtained by means of a series/parallel
primary, and the accuracy rating marked on the nameplate covering
both ratios is 0.388.9.

These units are for the Calgary Power Company Limited for use
in Janet Substation.

H.J.C. Fraser,
Chief,
Electricity and Gas Division,
Standards Branch.

c.c. Mr. A. S. Park, D.I. of 526 Calgary
Calgary Power Co. (through Mr. Park)