

SPE-0141

SPE-0141

4-13-35
SPE-0141-175V
SPE-0141-176

Ottawa, January 11, 1960.

TELEGRAM

Granted to: Canadian Westinghouse Limited,
London, Ontario.

Subject: One only, Canadian Westinghouse Type A 3000
KVA-5 primary Current Transformer, "Serial
No. 003 1122-01 and 1122-02.

Attention: Mr. J. R. K. A.,
Electrical Department

A special approval has been granted by the Standards Branch
for use in Canada for Billing purposes to the above-named apparatus.

Their transformers are the through type with a single secondary
winding, and has an accuracy rating of 0.1% D marked on the nameplate.

They are formed at the Peterborough Works, Peterborough,
Ontario.

63A D. 175V
1122-01, 02

Engineering Division,
Standards Branch.

C.C. P.D. C. M. L. S. E.
Mc Gregor, Peterborough, Ontario.