

SPE-0142

SI-112

SI-110-77

SI-110-10

SI-110-SPE

OTTAWA, February 3, 1959.

SPECIAL APPROVAL

Granted to: Gas Turbine Company of Canada Limited,
Montreal, P. Q.

Subject: Three only, Gas Turbine Company Limited Type BT6
Voltage Transformers. Serials 225014, 225011, 225012

Attention: Mr. Claude Ford,
Communications Engineer.

Special Approval has been granted by the Standards Branch for use in Canada for filling purposes to the above-named apparatus.

These transformers are for use by Bagnoney Power Company at their installation registered on Form SA-44 as Installation No. PA-1502. The customer is Hydro-Quebec.

This installation must be inspected and it must be determined that the overall accuracy of the combination of the main voltage transformers and the subject auxiliaries is acceptable.

J. J. ...
Electricity and Gas Division,
Standards Branch.

C.C. F. ...