

SL - 146

SL-85-1-5
SL-100-982(v)
SL-100-3PF

OTTAWA, May 21, 1969.

SPECIAL APPROVAL

Granted to: Ferranti-Packard Limited,
St. Catharines, Ontario.

Subject: Three Only Ferranti-Packard Type "C" Current
Transformers, 10000-5 ampe., 60 volts, 60 hz
Indoor Dry Type serial numbers 2-230969-570-971

Attention: Mr. E. L. Mills, Manager
Instrument Transformer Engineering

Special Approval has been granted by the Standards Branch for
use in Canada for billing purposes to the above-named apparatus.

These transformers are the through type with the series connected
secondary coils wound on each leg of a built-up core.

The accuracy rating is 0.3%0.1, 10.2, 50.5, 10.5, 51.0,
B(2x0.9), 2.0 and the nameplates are marked 0.3%0.9.

These transformers are for use at C.P.C.C. Ltd., Trillia, by
the Trillia Light and Power Commission.

kA/mh

J. D. Fraser,
Chief, Electricity and Gas Division

C.C.C. Mr. J. W. Brown, P.I.O. of C.L., Toronto
Trillia Light and Power Commission (through Mr. J. Brown)