

SPE-146

SE-85-1-1
SL-100-601
SL-100-SPE

OTTAWA, June 3, 1969.

SPECIAL APPROVAL

Granted to: Canadian General Electric Co. Ltd.,
1130 Blvd., Charest West,
Quebec 8, P.Q.

Subject: One C.G.E. Type V-620 two element
watthour meter, marked single phase
2-wire, 1.2-100 ampere, 600 volt, 60
cycle, K_1 18.0, serial 3827196

Attention: Mr. E. B. Foster,
Manager, Meter Sales.

Special Approval has been granted by the Standards Branch for use in Canada for billing purposes, to the one meter noted above. This meter has a register of 111 1/9 and a multiplier of 10 neither of which are marked on the nameplate.

This meter is to be used by The Department of Indian Affairs "Obedjiwan Reserve".

W. J. S. Fraser,
Chief, Electricity and Gas Division,
Standards Branch.

c.c. Mr. J. Dumas, D.I. of Montreal
Dept. of Indian Affairs (through Mr. Dumas)
Regional Office Montreal