

SPX-119

SI-85-2-1
SI-KC-89 (AV)
SI-100-SPX

OTTAWA, July 9, 1969.

SPECIAL APPROVAL

Granted to Canadian Westinghouse Company Limited,
P.O. Box 510,
Hamilton, Ontario.

Subject: 5 dial clock registers without test dials

Attention: Mr. V. L. Campbell, Manager,
Production Engineering, Electrical Products
Division, Hamilton, Ontario, Canada.

Special Approval has been granted by the Standards Branch
for use in Canada for billing purposes to the above-named apparatus.

These registers have a register ratio of 360 and will be in-
stalled on Canadian Westinghouse Types (CA) and (CS-1) single phase
amphour meters, with a nominal rating of 25 amperes and a disc
constant of $1 \frac{1}{3}$, by the British Columbia Hydro and Power Authority.

W. J. S. Fraser

W. J. S. Fraser,
Chief,
Electricity and Gas Division,
Standards Branch.

c.c. Mr. R.G.D. Ward, D.I. of B.C., Vancouver
Mr. Noel Clark, B.C. Hydro and Power Authority
Mr. P. J. Blaine, Regional Manager, Vancouver.