

Book
SPE-150

SE-69-15
SL-100-913
EL-100-136
EL-100-SPE

OTTAWA, July 17, 1969.

SPECIAL APPROVAL

Granted to: Aluminum Company of Canada, Ltd.,
Jonquiere, P.Q.

Subject: Three - Brown Boveri Current Transformers
Type TMRG-275, 275/440 Kv., 60 Hz.
800/400-5-5-5 Amps
Accuracy Class 0.3 at 20 VA
Serial Nos. B206628, B206629, B206630

Three - Brown Boveri Potential Transformers
Type TMSd-220, 220/440 Kv., 60 Hz.,
Ratio $230000/\sqrt{3}$ $115/\sqrt{3}$
2000:1
Accuracy Class 0.3 at 150 VA
Serial Nos. B137691, B137692, B137693

Attention: Mr. Claude Lord,
Communications Engineer.

Special Approval has been granted, by the Standards Branch, for use in Canada, for billing purposes, to the six instrument transformers noted above.

They are installed at the Isle Maligne plant of the Aluminum Co. of Canada, Installation No. 240692.

W. J. S. Fraser
W. J. S. Fraser,
Chief, Electricity and Gas Division,
Standards Branch.

c.c. Mr. J. C. Bedard, D.I. of EEG, Quebec
Mr. Etienne Laranger, Regional Manager, Montreal