

SPE-153

SI-105-S-1
SI-100-S
SI-100-SPE

OTTAWA, September 4, 1969.

SPECIAL APPROVAL

Granted to: Canadian Westinghouse Company Limited,
P.O. Box 520,
Hamilton, Ontario.

Subject: 5 dial clock registers without test dial.

Attention: Mr. W. H. Campbell, Manager,
Production Engineering, Standard Products,
Switchgear and Control Division.

Special Approval has been granted by the Standards Branch
for use in Canada for billing purposes to the above-named apparatus.

These registers have a register ratio of $27 \frac{7}{9}$ for use on the
Westinghouse "D" Line single phase watt-hour meters, with a rating of
.75-100 amperes and a disc constant of 3.6, by the British Columbia
Hydro and Power Authority.

W. J. S. Fraser,
Chief,
Electricity and Gas Division,
Standards Branch.

c.c. Mr. R.G.D. Ward, D.I. of Vancouver
Mr. Noel Clark, B.C. Hydro and Power Authority
Mr. P. D. Dicene, Regional Manager, Vancouver.