

SPE-157

SL-100-353 (o)
SE-85-5-3
SL-100-SPE

OTTAWA, October 21, 1969.

SPECIAL APPROVAL

Granted to: Ontario Hydro, Central Region,
5760 Yonge Street,
Willowdale, Ontario.

Subject: One Only - English Electric Type "MO"
26400-110/110 Volt Potential Transformer,
Serial Number 174106.

Attention: Mr. F. A. Pertulla,
Regional Protection & Control Eng.,
Central Region.

Special Approval has been granted by the Standards Branch for
use in Canada for billing purposes, to the above-noted transformer.

From information available to us, we believe the accuracy rating
to be 1.2% WXYZ, etc.

This transformer is used as part of the metering equipment at
Douglas Aircraft Company, Sub. 41 at Malton.

EAB/amb
W. J. S. Fraser,
Chief, Electricity and Gas Division.

c.c. Mr. N. R. Malton, D.I. of H&D, Toronto
Mr. J. Kokesh, Regional Manager
Mr. K. C. Foster, Director, Operations Branch.