

SPE-0158

10-19

10-15-33

10-100-01

10-100-01E

OTTAWA, October 29, 1969.

MEMORANDUM

Granted to: Union Electric S.S. - N.V.  
 Rue de Verdun,  
 Maje, Belgium

Subject: Six only, Valenta type "T-1120" 130 kv. 60 Hz  
 500 x 100 -9-5 ampere, outdoor, oil insulated current  
 Transformers, serial numbers 5201-01, -02, -03, -04,  
 -05, -06.

Attention: Mr. L. Grignon,  
 Export Manager.

Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to the above-named applicants.

These transformers are post type with links at the top of the transformer whereby the two primary windings can be connected in series or in parallel to obtain either of the two ratios. Each transformer has two un-tapped secondary windings, identified in the terminal box at the base of the transformer as "11,2" for one winding, "11,12" for the other.

The vector of rating of either winding is 0.33:1, 10:1, 10.5; 0.3:0.9, 11:0, 11.0, 12:0 and the nameplates are rated 0.3 k.v.

These transformers are for use by the P.Q. Hydro & Power Authority.

*G.W. Anderson*

G.W. Anderson,  
 Assistant Director & Chief Engineer

(for)

C. J. S. Fraser,  
 Chief, Electricity & Gas Division.

- c.c. Mr. J.C.L. Ward, P.E., Vice-President
- H.Q. Hydro & Power Authority, (if not in Mr. Ward)
- Mr. W. H. Fisher, Branch Electric
- Mr. L. G. Foster
- Mr. J. T. Brown, Regional Manager