

SPE-0160

SPE - 100

SI-5-9

SI-100-971, (J)

SI-100-113

OTTAWA, October 30, 1969.

SPECIAL APPROVAL

Granted to: I.T.S. Circuit Breaker (Canada) Limited,
Eastern Power Devices Division,
2101 Glad Road,
Port Credit, Ontario.

Subject: Three Only, I.T.S. circuit breaker (Canada) Type "W015A1"
15kv., (60hz., 1600-5 amp. Current Transformers, Serial
Numbers 3556, 3557 and 3558

Attention: Mr. D. W. Gardner, Chief Engineer,
Transformer, Rectifier & Capacitor Section

Special Approval has been granted by the Standards Branch, for use
in Canada for billing purposes, to the above-named apparatus.

These transformers are through type with single untapped secondary
windings, the ends of which are brought to terminals marked "X1", "X2".

The accuracy ratio of these transformers is 0.5% up to and in-
cluding 0.302.0 with 0.302.0 tolerance, marked on the nameplates.

These transformers are made in Canada by I.T.S. Circuit Breaker and
are for use by Nepon Hydro Electric Commission, Ottawa, Ont.

[Signature]
C. L. Anderson,
Assistant Director & Chief Engineer.

EMW/mh

(For) M. G. S. Fraser,
Chief, Electricity and Gas Division.

c.c. Mr. J. F. Miller, S.T. of NE, Ottawa
Nepon Hydro Electric Commission (through Mr. Miller)
Mr. G. Lokesh, Regional Manager
Mr. H. G. Foster, Director, Operations Branch.