

PE-101

SL-100-444 (J)  
SL-100-545

OTTAWA, November 6, 1969.

SPECIAL APPROVAL

Granted to: Canadian General Electric Co., Ltd.,

940 Lansdowne Avenue,  
Toronto, Ontario.

Subject: Three Cyl., Canadian General Electric Type "KG-138"  
134kv., 60 hz., 1400AUX/1000-5-5 amperes and  
8000AUX-5 amperes Current Transformers, serial numbers  
707620, 707621 and 707622.

Attention: Mr. H. D. Maguire,  
Manager—Engineering,  
Distribution & Specialty Transformer Section

Special approval has been granted by the Standards Branch for use  
in Canada for billing purposes, to the above-named apparatus.

Each of these transformers has two primary windings and three secondary  
windings.

The two primary windings can be connected in series or in parallel  
by means of links.

Two of the secondary windings are tapped and are identified as the  
"Y<sub>1</sub>" and "Y<sub>2</sub>" winding with terminals Y<sub>1</sub>, Y<sub>2</sub>, Y<sub>3</sub>, Y<sub>4</sub> and Z<sub>1</sub>, Z<sub>2</sub>, Z<sub>3</sub>, Z<sub>4</sub> respectively.  
The third, or "Y<sub>4</sub>" winding is untapped and has terminals identified as  
Z<sub>1</sub>, Z<sub>2</sub> only.

Only the following ratios and connections are covered by this approval:  
Parallel Primary Connections

ratio secondary terminals accuracy rating at 60 hz on no-load  
1200-5 amperes Y<sub>1</sub>-Y<sub>2</sub>, Z<sub>1</sub>-Z<sub>2</sub> 0.3B2.0  
800-5 amperes Z<sub>1</sub>-Z<sub>2</sub>, Y<sub>1</sub>-Y<sub>2</sub>, Z<sub>1</sub>-Z<sub>2</sub> 0.3H2.0

Series Primary Connections

ratio	accuracy rating at 100A on secondary
11-5 ampe	0.312.0
100-5 ampe	0.312.0
200-5 ampe	0.611.0

XI, XII and 21 have the same polarity as II.

The accuracy rating is 0.3B.U.1, B0.2, B0.5, B0.9, B1.0, B1.8, B2.0 for the 100-5 and 11-5 ampe ratios if the "X" winding and the 120-5, 110-5, 600-5 and 400-5 ampe ratios of the "Y" and "Z" windings and 0.60.1, B0.2, B0.5, B0.9, B1.0, B1.8, B2.0 for the 200-5 ampe ratio of the "Y" and "Z" windings.

The insulation given the connections and the accuracy ratings are listed above.

These transformers are for use by the Calgary Power Limited at the  
Calgary Sub-stations.

G. M. Anderson,  
Assistant Director & Chief Engineer

(for) W. J. S. Fraser,  
Chief, Electricity and Gas Division.

W. J. S. Fraser, P.I. of E&G Calgary  
Calgary Power Limited (through Mr. Park)  
Mr. R. H. Hickay, Regional Manager  
Mr. K. C. Foster, Director, Operations Branch.