


Department of consumer and corporate affairs/Ministère de la consommation et des corporations



SPE-165

SE-69-1 SL-100-813 SL-100-SPE

OTTAWA, December 9, 1969.

## SPECIAL APPROVAL

Granted to:

Ontario Hydro,

Eastern Region,

P.O. Box 40, Belleville, Ont.

Subject:

Four Only, English Electric Type "RO-46" 400/200-5 amp 46 kv. 60hz, Current Transformers, Serial Numbers 189756, 189758,

189759 and 200485.

Attention:

Mr. A. J. Fort,

Regional P & C Engineer,

Eastern Region.

Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to the above-named apparatus.

From information at hand, it is considered that the accuracy rating of these transformers is 0.3B0.1, B0.2, B0.5; 0.6B0.9 on both ratios.

These transformers are in use at Dupont of Canada Limited, Kingston, Ontario as part of Hydro installation #E-35.

W.J.S. Fraser,

Chief.

Electricity and Gas Division.

c.c. Mr. T. G. Murphy, D.I. of E&G, Belleville
Mr. J. Kokesh, Regional Manager, Toronto

Dupont of Canada Limited, Kingston, Ontario: forwarded through

Mr. T. G. Murphy