SE-65-18-1 SL-100-456(B) SL-100-SPE

OTTAWA, February 12, 1970.

SPECIAL APPROVAL

Granted to:

Canadian ASEA Electric Limited,

One Bentall Centre, Vancouver 1, B.C.

Subject:

Ten Only A.S.E.A. Type "EFFC145", 78000-120-120 volts,

60 hz, Voltage Transformers, serial numbers 9169491-

492-493-494-495-496-497-498-499-500.

RK

Attention:

Mr. S. Thomson, Assistant Manager.

Special Approval has been granted by the Standards Branch for use in Canada for revenue purposes to the above-named apparatus.

These transformers have a single primary winding and two identical untapped secondary windings.

The accuracy rating of this transformer is 0.6WXYZ on either secondary winding with the other secondary unloaded, and 0.6Z-0.6Z with Z burden on both windings simultaneously loaded.

These transformers are for use by the B.C. Hydro and Power Authority of Vancouver, B.C.

W.J.S. Fraser, Chief,

Electricity and Gas Division.

c.c. Mr. R.G.D. Ward, D.I. of E&G, Vancouver B.C. Hydro (through Mr. Ward) Mr. P. E. Dionne, Regional Manager, Vancouver.