

SPE-0171

SPE-171

SL-85-18-1  
SL-100-758  
SL-100-SPE

OTTAWA, February 19/70

SPECIAL APPROVAL

Granted to: Canadian ASEA Electric Limited,  
3350 American Drive,  
Malton, Ontario.

Subject: Six Only A.S.E.A. Type "CUFA 220" Voltage Transformers,  
138000-151800 primary volts 69-69 secondary volts 60 Hz  
ratios 2000-1 and 2200-1, serial numbers 6167183, -184,  
-185, -186, -187 and -188

Attention: Mr. J. G. Reid, P. Eng.,  
Lower Department

Special Approval has been granted by the Standards Branch for use  
in Canada for billing purposes, to the above-named apparatus.

These transformers are capacitor type with the capacitors stacked  
vertically and insulated from each other by means of porcelain insulators.  
The entire assembly is mounted on a metal housing containing the inter-  
mediate voltage transformer with its primary and secondary windings.

This special approval is valid only when each intermediate voltage  
transformer is associated with the following capacitors and their arrange-  
ment as given in the attached drawings:

serial 6167183 capacitors 8.20 $\mu$ /1, 8.20 $\mu$ /2, 8.20 $\mu$ /3, 8.20 $\mu$ /4,  
8.20 $\mu$ /5, 8.20 $\mu$ /6, 8.20 $\mu$ /7, 8.20 $\mu$ /8, 8.20 $\mu$ /9, 8.20 $\mu$ /10  
Rack No 20. Drawing K49831486 No. 1  
serial 6167184, capacitors 8.20 $\mu$ /11, 8.20 $\mu$ /12, 8.20 $\mu$ /13, 8.20 $\mu$ /14,  
8.20 $\mu$ /15, 8.20 $\mu$ /16, 8.20 $\mu$ /17, 8.20 $\mu$ /18, 8.20 $\mu$ /19, 8.20 $\mu$ /20  
Rack No 21. Drawing K49831486 No. 2

serial 6167183, capacitors 8.20M/21, 8.20M/22, 8.20M/23, 8.20M/24,  
8.20M/26, 8.20M/27, 8.20M/28, 8.20M/29, 8.20M/30,  
8.20M/32  
stack no 22. Drawing K49831486 No. 3  
serial 6167186, capacitors 8.20M/25, 8.20M/31, 8.20M/33, 8.20M/34,  
8.20M/35, 8.20M/36, 8.20M/37, 8.20M/38, 8.20M/39,  
8.20M/60  
stack no 23. Drawing K49831486 No. 4  
serial 6167187, capacitors 8.20M/40, 8.20M/41, 8.20M/43, 8.20M/44,  
8.20M/45, 8.20M/46, 8.20M/47, 8.20M/48, 8.20M/49,  
8.20M/42  
stack no 24. Drawing K49831486 No. 5  
serial 6167188 capacitors, 8.20M/50, 8.20M/51, 8.20M/52, 8.20M/139,  
8.20M/541, 8.20M/55, 8.20M/56, 8.20M/57, 8.20M/58,  
8.20M/59  
stack 25 Drawing K49831486 No 6.

The capacitors in the stacks are type CTOA 1/220 rated at  
25.3/√3 kv.

The intermediate voltage transformers are type 2000 24A with serial  
numbers listed at the beginning of this letter.

These intermediate voltage transformers are rated at 13.6-15.18kv;  
each has two identical untapped secondary windings producing 69 volts with  
rated primary volts.

Each transformer has two nominal ratios, 2000-1 and 1200-1 and the  
change from one to the other is made by means of taps at an oil-immersed  
terminal block behind a removable cover. The position of the tap cannot  
be ascertained without removing this cover.

Each transformer has trimming windings with connections to a terminal  
block for adjustment on the opposite side to the secondary terminals.

This approval is valid only for the following connections at the  
adjustment terminals:-

serial 6167183 E9-B8-135, B6-B4, B3-B2, B1-B2  
serial 6167184 B9-B8-B6-B3, B4-B1, B2-B2  
serial 6167185 B9-B8-B5, B6-B4, B3-B2, B1-B2  
serial 6167186 B9-B8-B6-B4-B1, B2-B2  
serial 6167187 B9-B8-B5, B6-B4-B2, B1-B2  
serial 6167188 B9-B8-B5, B6-B4-B2, B1-B2

These connections are valid for both of the ratios.

Transformers with serial numbers 6167184 and 6167185 are equipped  
with carrier boxes serial 6164734 and 6164730 respectively.

Placing the carrier drain coil in or out of the circuit does not require changing the connections and it does not have any effect on the accuracy rating.

Each transformer has two identical secondary windings with terminals marked A1, A2 and Y1, Y2 respectively.

"X1" and "Y1" have the same polarity as "H1" on the top of the top of the capacitor stack.

The accuracy rating of these transformers is 0.5% on either secondary with the other secondary unloaded and 0.6%/0.6% with both secondaries loaded with "Z" burden.

The nameplates are marked 0.6%/0.6%.

These transformers are for use by Ontario Hydro at the Mississauga Transformer Station.

A. J. S. Fraser,  
Chief,  
Electricity and Gas Division,  
Standards Branch.

C. C. W. R. McEown, P.E. of I&E, Toronto  
Ontario Hydro (through Mr. W. R. McEown)  
Mr. J. W. McKesh, Regional Manager, Toronto