

SPE-0174

100-1000

100-1000
100-1000

OTTAWA, April 26, 1976.

Transmitting Office:

Subject to: Ferranti-Randall Limited,
St. Catharines, Ontario.

Subject: All the 6 kV Ferranti-Randall type 3142560-65 exp.,
shunt voltage 63 Hz, bushings and mounted supports
transformers located at locations 1-142560-61-65 and
2-142560-61-65.

Numbered: 170-1000, 100-1000
2-1000, 100-1000, 100-1000.

Specified by: will be accounted by the Standards Branch
for use in Canada for billing purposes to the above-named apparatus.

These transformers are having type oil immersed, with a single
secondary winding.

The accuracy rating of the transformer is 0.5% C.W. with a
rating factor of 1.33. The name plate number is 142560-65.

These transformers are for use by the Hydro-Electric Power
Commission of Ontario who will use transformer 1-142560-61-65
at the London-Highway 28 831-1144 and transformers 2-142560-61-62-
63 at Toronto-Fairbanks 28 831-1309.

W.J.B. Fraser,
Chief, Electricity and Gas Division.

cc: Mr. J. Flaman, D.L. of C., London
Mr. W. G. Benham, D.L. of C., Toronto
Ontario Hydro (through Mr. Flaman)