

Ministère des consommateurs et des corporations - Ministère de la consommation et des corporations

SPE-0175

SP-175

SL-30-1-6
SL-100-1025
SL-100-S-1

Ottawa, April 19, 1970.

Canadian General Electric

Dear Madam or Sir:
Canadian General Electric Co. Ltd.,
970 Lakeshore Road,
Toronto 4, Ontario.

Subject: Three Only, Canadian General Electric Type "CY-1M"
250000 kva 1/13000-115/69-115/69 volts 60 Hz serial
numbers 707626, 707627 and 707628.

Attention: Mrs. M. R. McMurtry,
Manager, Technical Services,
Distribution & Specialty Transformers

Special approval has been granted by the Standards Branch
for use in Canada for testing purposes to the above-named apparatus.

These capacitor voltage transformers are each an assembly of one coupling capacitor and a three-unit linking a type PY-1D intermediate voltage transformer, followed by a protective enclosure.

It is very important that the cap filter units bear the same serial numbers on their respective bases.

The metering accuracy rating is 0.6% on either secondary
with the other secondary open and 0.6% on either secondary with the
other secondary loaded with 1 ohm load. This applies to both ratios.
The accuracy rating marked on the nameplate is 0.6%.

- 1 -

This approval is valid only for the following connections:

serial 707625

H3 on potential transformer to A on reactor
I on potential transformer to 5 on reactor
A to D on potential transformer
3 on potential transformer to ground
A to 7 on reactor

serial 707627

H3 on potential transformer to 14 on reactor
I on potential transformer to 7 on reactor
A to D on potential transformer
B on potential transformer to ground
2 to 8 on reactor

serial 707628

H3 on potential transformer to 14 on reactor
F on potential transformer to 3 on reactor
A to D on potential transformer
B on potential transformer to ground
2 to 8 on reactor

Each of these transformers contain carrier equipment but the accuracy rating does not change whether this equipment is on or off.

These transformers are for use by B.C. Hydro and Power Authority for installation at Ingledow substation.

These three units are the first of a group of seven that will be used to replace seven similar units serial numbers 531078, 531079, 531080, 531082, 531083 and 531084 that received special approval on September 13, 1965 and number 514019 that received special approval on January 10, 1968.

W.J.B. Fraser,
Chief, Electricity and Gas Division,
Standards Branch.

c.c. Mr. R.G.D. Ward, B.I. of Int'l Vancouver
B.C. Hydro (forwarded through Mr. Ward)