

SPE-177

SE-85-1-5  
SL-100-221A  
SL-100-SPE

OTTAWA, May 12, 1970.

SPECIAL APPROVAL

Granted to: Canadian General Electric Company Limited,  
940 Lansdowne Avenue,  
Toronto 4, Ontario.

Subject: Two Only Canadian General Electric Type "IS-69"  
69kv, 60Hz, 400/200/100-5-5 Current Transformers,  
Serial numbers 741649 and 741650.

Attention: Mr. R. D. Maguire, Manager-Engineering  
Distribution and Specialty Transformers Section.

Special Approval has been granted by the Standards Branch for use in Canada for billing purposes, to the above-named apparatus.

Each of these transformers has a single primary and two tapped secondary windings, the latter with leads brought to a terminal block and identified as X1, X2, X3, X4; Y1, Y2, Y3 and Y4.

The 400-5 amp. ratio is available from terminals X1, X4 and Y1-Y4; the 200-5 amp. ratio is available from X1, X3 and Y1, Y3 and the 100-5 amp. ratio is available from X1, X2 and Y1, Y2.

The accuracy ratings are 0.3B2.0 for the 400-5 and 200-5 amp. ratios and 0.3B0.9 for the 100-5 amp. ratio.

The nameplates are marked 0.3B2.0 for the 400-5 and 200-5 amp. ratios and 0.6B0.9 for the 100-5 amp. ratios.

These transformers are for use by Manitoba Hydro for installation at Thompson, Manitoba.

*W.J.S. Fraser*

W.J.S. Fraser,  
Chief, Electricity and Gas  
Division.

c.c. Mr. N.H. Young, D.I. of E&G, Winnipeg  
Manitoba Hydro (through Mr. Young)