

100-1000-100-100

SPE-0178

100-1000-100-100
100-1000-100-100
100-1000-100-100
100-1000-100-100

Ottawa, Aug 27, 1970.

TELEGRAM

TO: Mr. G. J. M. HARRIS

100-1000-100-100
100-1000-100-100
100-1000-100-100

Subject:

Technical opinion of relays for telemetering.

Attention:

Mr. ... J. E.,
100-1000-100-100
100-1000-100-100
100-1000-100-100

A technical proposal has been granted by the Standards branch to Hydromet to install a set of relays, outlined on attached schematic, 100-1000-100-100, for pulse transmission and reception in telephone line links.

Please advise if there is any wiring or layout of the transmitting unit similar to the receiving unit. The physical arrangement of the receiving unit. In both cases the two relays are mounted on one 2" x 1" side of the Hammond utility box, one terminal block is mounted on the same face on the long side opposite the relays and the remaining components are enclosed within the box.

It would be most welcome the mechanical arrangement of these units is such as to permit them in the field position; the relays are enclosed, there are no tools on the utility box and the terminal blocks are unaccessible unless the units are located in a locked room or enclosure. They may be subject to occasional disturbance or casual tampering.

W.E.S. Branch,
Chief,
Electricity and Gas Divn.

cc: Mr. G. S. Lunn, Manager, E.G.
cc: Mr. John Williams, Manager, P.D.
cc: Mr. G. M. Dunn, Head Division, E.G.
cc: Mr. G. M. Dunn, Manager, Telecommunications
cc: Mr. G. S. Lunn, Manager, Utilities, E.G.