

Department of consumer and corporate affairs, Ministère de la consommation et des corporations

SPN-179

SE-35-4-5  
SL-100-953 (Y)  
SL-100-SPE

OTTAWA, June 8, 1970.

SPECIAL APPROVAL

Granted to: Ferranti-Packard Limited,  
St. Catharines, Ontario.

Subject: Three only, Ferranti-Packard Type "K"  
4000/2000-5amp., 600 Volt 60 hz Current  
Transformers.  
Serial Numbers 2-242683-684-685.

Attention: Mr. E.L. Mills, Manager  
Instrument Transformer Engineering.

Special Approval has been granted by the Standards Branch for  
use in Canada for billing purposes, to the above-named apparatus.

These transformers are bushing type with tapped secondary  
windings with terminals marked "X1", "X2" and "X3".

The 4000-5 and 2000-5 amp. ratios are obtained using secondary  
terminals X1-X3 and X1-X2 respectively.

The accuracy rating of each transformer on both ratios is  
0.3%O.O and the nameplates are marked 0.3%O.9.

These transformers are installed in a 1500 KVA power trans-  
former for Calgary Power Limited and installed in the vicinity of  
Rocky Mountain House.

*J. J. Fraser*  
(for) W.J.S. Fraser,  
Chief,  
Electricity and Gas Div.,  
Standards Branch.

cc: Mr. A.S. Park, D.I. Eng Calgary  
Calgary Power (through Mr. Park)