

SPE-180

SE-85-92
SL-100-913A
SL-100-SPE

OTTAWA, July 2, 1970.

SPECIAL APPROVAL

Granted to: Aluminum Company of Canada Ltd.,
Jonquiere, Quebec.

Subject: One Only - Brown Boveri Current Transformer
Type TMBRg 275, 275/460 kv, 60hz
800/400-5-5-5 Amps., Serial Number B-206633


Attention: Mr. Claude Lord,
Communications Engineer.

Special Approval has been granted by the Standards Branch, for use in Canada, for billing purposes, to the above-noted current transformer.

This transformer has 3 secondary windings, identified as cores 1, 2 and 3, but only core 1 is covered by this approval.

The accuracy class of this core is 0.3 at a burden of 20VA 0.5 power factor.

This transformer is presently a spare unit.



W.J.S. Fraser,
Chief,
Electricity and Gas Division.

c.c. Mr. J. O. Bedard, D.I. of E&G, Quebec