



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



SPE-181  
SE-85-4-5  
SL-100-596 (0)  
SL-100-SPE

OTTAWA, July 13, 1970.

SPECIAL APPROVAL

Granted to: Ferranti-Packard Limited,  
St. Catharines,  
Ontario.

Subject: Two Only, Ferranti-Packard Type "KMD35" 1000/2000-5  
amp., 17250/29800-115 volt 60 hz, 3 phase 4 wire Outdoor  
Oil-filled Metering Outfits, serial nos. 2-242548 and  
2-242549.

Attention: Mr. E. L. Mills, Manager  
Instrument Transformer Engineering.

Special Approval has been granted by the Standards Branch for use  
in Canada for billing purposes to the above-named apparatus.

Each metering outfit contains 3 type "MC35" voltage transformers  
and 3 type "RB Special" current transformers.

Metering outfit 2-242548 contains voltage transformers serial numbers  
2-242536-537-538 and current transformers serial numbers 2-242542-543-544.

Metering outfit 2-242549 contains voltage transformers serial numbers  
2-242539-540-541 and current transformers serial numbers 2-242545-546-547.

Each voltage transformer is single ratio and an accuracy rating of  
0.3WXYZ;0.6ZZ.

Each current transformer is double ratio obtained by means of a  
tapped secondary winding with an accuracy rating on both ratios of 0.3B2.0.

The nameplate is marked 0.3Z for the voltage transformers and 0.3B0.9  
for the current transformers.

These metering outfits are for installation at the Ford Motor Company plant at Windsor, Ontario.

W.J.S. Fraser,  
Chief,  
Electricity and Gas Division,  
Standards Branch.

c.c. Mr. J. Fleming, D.I. of E&G, London  
Ford Motor Company (through Mr. Fleming)