



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



SPE-182

SE-85-2-1  
SL-100-89(AW)  
SL-100-SPE

OTTAWA, July 24, 1970.

SPECIAL APPROVAL

Granted to: Canadian Westinghouse Company Limited,  
P.O. Box 510,  
Hamilton, Ontario.

Subject: 5-dial Clock Registers without test dials

Attention: Mr. V. E. Campbell, Manager  
Production Engineering, Products Branch  
Switchgear and Control Division.

Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to the above-named apparatus.

These registers have a register ratio of 27 7/9 for use on the Canadian Westinghouse "D" line single phase watthour meters, with a rating of .75-100 amperes and a disc constant of 3.6 by the Saskatchewan Power Corporation.

W.J.S. Fraser,  
Chief,  
Electricity and Gas Division.

c.c. Mr. J. Duff, D.I. of E&G, Regina  
Saskatchewan Power Corporation (through Mr. Duff)  
Mr. R. H. McKay, Regional Manager, Winnipeg