



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



SPE-183

SE-85-4
SL-100-E
SL-100-SPE

OTTAWA, August 27, 1970.

SPECIAL APPROVAL

Granted to: Saskatchewan Power Corporation,
Regina, Saskatchewan.

Subject: Conversion of 5-Dial XI to 4-Dial XI0 Clock
Registers by means of a "Mult. X 10" tag on
the lowest reading units dial.

Attention: Mr. W. E. Thompson,
Metering Engineer.

Special Approval has been granted by the Standards Branch
for use in Canada for billing purposes to the above-noted conversion.

The meters on which these converted registers are approved
for use are Sangamo type CJ, Canadian General Electric Types I-55,
I-60 and I-70, Canadian Westinghouse types D3 and D4 and Ferranti-
Packard types B3 and B4.

These tags are manufactured by Sangamo Company and are
illustrated on circular E-38 and all, with the exception of those
used on Sangamo CJ meters, are trimmed at the top to permit a portion
of the divisions of the first dial to be observed, and have the hole
slightly enlarged to give shaft clearance.

W. J. S. Fraser

W.J.S. Fraser,
Chief,
Electricity and Gas Division.

c.c. Mr. J. Duff, D.I. of E&G, Regina
Mr. R. H. McKay, Regional Manager, Winnipeg.