



Department of Consumer and Corporate Affairs / Ministère de la consommation et des corporations



SPE-186

SE-85-9
SL-100-974(L)
SL-100-SPE

OTTAWA, September 17, 1970.

SPECIAL APPROVAL

Granted to: I.T.E. Circuit Breaker (Canada) Limited,
Eastern Power Devices Division,
2401 Dixie Road,
Port Credit, Ontario.

Subject: Six Only, I.T.E. Circuit Breaker Type "M015M1" 15kv
3200/1600-5 amp., 60 hz, Current Transformers Serial
Numbers 4688, 89, 90, 91, 92, 93.

Attention; Mr. D. W. Gardner, Chief Engineer,
Transformer, Rectifier & Capacitor Section.

Special Approval has been granted by the Standards Branch, for use in Canada for billing purposes, to the above-named apparatus.

These transformers are through type with tapped secondary windings.

There are three secondary terminals marked "X1", "X2" and "X3". The 3200-5 amp. ratio is from terminals "X1" and "X3" and the 1600-5 amp. ratio from terminals "X1" and "X2". Polarity is indicated by white dots adjacent to "H1" and "X1", and R.F. = 1.

The accuracy rating that applies to both ratios is 0.3B2.0 and the nameplates are marked 0.3B0.9;0.6B(2x0.9).

These transformers are for use by Ontario Hydro at the Hamilton-Birmingham substation.

W.J.S. Fraser,
Chief, Electricity & Gas Division.

c.c. Mr. R. N. Beattie - Hamilton
Mr. W. R. McEown - Toronto
Ontario Hydro (through Mr. McEown)

Standards Branch
Direction des normes