



Department of consumer and corporate affairs / Ministère de la consommation et des corporations

SPE-188

SE-69-2
SL-100-2(Z)
SL-100-SPE

OTTAWA, October 19, 1970.

SPECIAL APPROVAL

Granted to: City of Calgary Electric System,
2808 Spiller Road S.E.,
Calgary 24, Alberta.

Attention: Mr. J. Minifie

Subject: Two Only Westinghouse Type "PTM" Voltage Transformers
14560GrdY/8400-120 volts 60hz, 15kv., Serial Numbers
6564863 and 6564864.

Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to the above-named apparatus.

The Standards Branch has been given assurance by Canadian Westinghouse that the above-noted transformers have characteristics quite similar to the type "PT-15" covered by circular S-EA.594.

The accuracy rating is therefore 0.3WXYZ;0.6ZZ.

These transformers are for use at the Western Co-Op Fertilizer Plant-Chemical & Industrial Corporation, Calgary, Alta.

W.J.S. Fraser,
Chief,
Electricity & Gas Division.

c.c. Mr. A. S. Park, D.I. of E&G, Calgary
Mr. R. H. McKay, Regional Manager
Western Co-Op Fertilizer Plant-Chemical & Industries Corp. (through
Mr. A. S. Park)