

SPE-0189

SPE-189

SL-85-2-6
SL-100-57(J)
SL-100-SPE

OTTAWA, October 22, 1970.

SPECIAL APPROVAL

Granted to: Canadian Westinghouse Company Ltd.,
P.O. Box 2220,
London, Ontario.

Attention: Mr. J. E. Highfield, Engineering Assistant,
Engineering Department,
Distribution Apparatus Division.

Subject: Twenty Four (24) Only Canadian Westinghouse Type
"RTFB" 600-5 ampere, 60hz, 15kv Current Transformers
Serial Numbers 693040 to 693069 inclusive.

Special Approval has been granted by the standards Branch
for use in Canada for billing purposes to the above-named apparatus.

The accuracy characteristics of these transformers are
similar to those of the type RT-15 of the same ratio covered by circular
T-15 and the nameplate is also marked with the accuracy rating
0.310.9.

These transformers are for use by Hydro-Quebec at the
Maisonneuve Sub-station at Westmount, Montreal, Quebec.

[Signature]
W.J.S. ...
Chief, Electricity & Gas Division.

c.c. Mr. J. B. Dumas, D.I. of H&G, Montreal
Hydro-Quebec (through Mr. Dumas)