



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



SPE-190

SE-25-9

SL-100-974(N)

SL-100-SPE

OTTAWA, October 30, 1970

SPECIAL APPROVAL

Granted to: I.T.E. Circuit Breaker (Canada) Limited,
Eastern Power Devices Division,
2401 Dixie Road,
Port Credit, Ontario.

Attention: Mr. D.W. Gardner, Chief Engineer,
Transformer, Rectifier & Capacitor Section

Subject: Four Only, I.T.E. Circuit Breakers Type
MCB15A 15kv., 3000-5 amp., 60 Hz., Current
Transformers Serial Numbers 4744, 4745, 4749
and 4750

Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to the above-named apparatus.

These transformers are through type with single untapped secondary windings.

The accuracy rating found by test is 0.332.0 and they have labels marked 0.3E0.2, E0.5, E0.9;0.6B(2x0.9).

These transformers are for use at Ecstall Mining Limited, Hoyle Township by Ontario Hydro at North Bay.

W.J.S. Fraser,
Chief,
Electricity and Gas Division.

cc: Mr. G.O. Piirainen, D.I. of M&G, Sudbury

Ontario Hydro at North Bay (through Mr. Piirainen)