



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



SPE-195 (Suppl 171)

SE-85-9
SL-100-974 (M)
SL-100-SPE

OTTAWA, November 24, 1970.

SPECIAL APPROVAL

Granted to: I.T.E. Circuit Breaker (Canada) Ltd.,
Eastern Power Devices Division,
2401 Dixie Road,
Port Credit, Ontario.

Attention: Mr. D. W. Gardner, Chief Engineer
Transformer, Rectifier & Capacitor Section.

Subject: One Only, I.T.E. Circuit Breaker Type MC15M1 15kv.,
3200/1600-5 amp., 60 hz Current Transformer Serial
Number 4970.

Special Approval has been granted by the Standards Branch
for use in Canada for billing purposes to the above-named apparatus.

This transformer is a through type with a single tapped
secondary winding.

The secondary terminals are marked X1, X2 and X3. The
3200-5 amp. ratio is obtained from terminals X1 and X3 and the 1600-5
amp. ratio from terminals X1 and X2.

The accuracy rating is 0.3B2.0 on both ratios and the name-
plate is marked 0.3B0.2, B0.5, B0.9;0.6B(2x0.9).

This transformer is for use at the Hamilton Birmingham Station,
Birmingham Street, Hamilton by Ontario Hydro.

This transformer is a replacement for another of the same type
and ratio, serial number 4939 which was damaged in shipment.

W.J.S. Fraser,
Chief, Electricity & Gas Division.

c.c. Mr. R. N. Beattie, Hamilton
Ontario Hydro at Hamilton (through Mr. Beattie)

Standards Branch
Direction des normes