



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



SPE-196

SE-85-2-6
SL-100-57(I)
SL-100-SPE

Ottawa, November 26, 1970.

SPECIAL APPROVAL

Granted to: Canadian Westinghouse Company Limited,
P.O. Box 2220,
London, Ontario

Subject: Nine only, Canadian Westinghouse Type "RCT-15"
1000/500-5 amp., 60 hz Current Transformers
Serial Numbers 699569-70-71-72-73-74-75-76-77

Attention: Mr. T.W. Kolator, P. Eng., Senior Engineer,
Engineering Department,
Distribution Apparatus Division.

Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to the above-named apparatus.

These transformers are bushing with tapped secondary windings with three secondary terminals marked "X1", "X2" and "X3".

The 500-5 amp., ratio is obtained from terminals "X1" and "X2" and the 1000-5 amp., ratio from terminals "X1" and "X3".

The 60 hz accuracy ratings are 0.3B2.0 for the 1000-5 amp., ratio and 0.3B1.0; 0.6B2.0 for the 500-5 amp., ratio and the nameplates are marked 0.3B0.9 at 60 hz without reference to ratio.

These transformers are for use by the City of Calgary at #34 Sub-station 2808, Spiller Road, S.E., Calgary 25, Alberta.

W.J.S. Fraser,
Chief, Electricity & Gas Division.

cc: Mr. A.S. Park, D.I. of E & G, Calgary.
cc: City of Calgary (Through Mr. Park)