



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



SE-89-1-1  
SL-100-330 (AD)  
SL-100-SPE  
(SPE-201)

OTTAWA, January 11, 1971

Special Approval

Granted to: Canadian General Electric Company Ltd.  
1130 Boulevard Charest  
Quebec 8, P.Q.

Attention: Mr. W.P. Peters  
Manager - Meter Sales

Subject: Canadian General Electric 5 dial x 1  
Clock Register Rr 162/3 without test  
dials for use as replacement on  
Canadian General Electric Type I-30A  
Single Phase Watthour Meters rated at  
25 amp., 230 volts

Special approval has been granted by the Standards Branch for use in Canada for billing purposes to 5-dial x 1 clock registers without test dials when installed on certain Canadian General Electric type I-30A single phase watthour meters of 25 amp., 230 volt rating.

The meters on which these registers are approved for use are the property of B.C. Hydro and Power Authority.

W.J.S.F. Fraser,  
Chief,  
Electricity and Gas Division.

cc: Mr. R.G.D. Ward, D.I. E&G Vancouver  
Mr. Noel Clark, B.C. Hydro (through Mr. Ward)