

SPE-0202

Department of Consumer and Corporate Affairs, Electricity Branch, Administration of the Corporation, etc.

100-100

100-100-1

100-100-100 (10)

100-100-100

Ottawa, January 22, 1971

SPECIAL APPROVAL

Granted to: National Harbours Board  
Montreal Harbour  
Montreal, Que. P.Q.

Attention: Mr. R. L. Lacombe

Subject: Nine Calypso Duplex Type 1250 Combination  
Demand Energy Meters Converted from 1,2-  
85 Ampere 120 Volts 2 Element Y to 0.12-  
7.5 Ampere 120 Volts 2 Element by the  
National Harbours Board, Serial Numbers  
6761176X, 6763710X, 6896613H, 6816707K,  
6761171H, 6816724X, 6873433X, 6816730H  
and 687600H

Special Approval has been granted by the Standards Branch  
for use in Canada for billing purposes to the above-named apparatus.

This conversion involved the replacement of the following  
components:

Both Voltage Coils  
Both Series Coils  
Both Current Transformers  
New Register Rr 6000

These meters are for use by the National Harbours Board in  
Montreal, Quebec.

W.J.S. Fraser,  
Chief,  
Electricity and Gas Division.

cc: Mr. L. Vachon, E&G, Montreal